

Certificate No.: SGS/240835

CERTIFICATE OF SUITABILITY

This certificate is issued by **SGS Australia Pty Ltd** in accordance with the SGS Electrical Type Testing Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and recognised by the Queensland Government Recognised External Certification Scheme (RECS). SGS certifies the electrical equipment described hereunder complies with the standard/s listed herein. It is a requirement that the electrical equipment supplied under this certificate shall be identical to the electrical equipment as certified. The electrical equipment may be marked with the regulatory compliance mark (RCM) in accordance with its conditions of use as set out in AS/NZS 4417.1 and the authorised marking as specified herein.

CERTIFICATE HOLDER

Company Name: Victron Energy B.V.
Address: De Paal 35, 1351JG, Almere, The Netherlands

CERTIFICATION DETAILS

Certification Standards: IEC 62109-1:2010 and IEC 62109-2:2011 and AS IEC 62477.1:2024 and AS/NZS 4777.2:2020 + A1
Comments/ Conditions: Nil
Authorised Marking: SGS-240835-E
Certificate Issue Date: 25 October 2024
Certificate Expiry Date: 24 October 2029

ELECTRICAL EQUIPMENT

Regulatory Definition: Nil
Description: Stand-Alone converter

Trade Name	Model Number	Ratings
MultiPlus-II	48/10000/140-100/100 230V	Battery: 38-66/48 Vdc, AC IN: 187-265 Vac; 235A / 100A; 8 kVA / 8 kW; 50/60 Hz; AC OUT: 230 Vac; 50/60 Hz; 36 A; 10 kVA / 8 kW DC OUT: 48 Vdc; 140 A Class I; IP21
MultiPlus-II	48/8000/110-100/100 230V	Battery: 38-66/48 Vdc, AC IN: 187-265 Vac; 188A / 100A; 6.4 kVA / 6.4 kW; 50/60 Hz; AC OUT: 230 Vac; 50/60 Hz; 29 A; 8 kVA / 6.4 kW DC OUT: 48 Vdc; 110 A Class I; IP21



For and On Behalf of
SGS Australia Pty Ltd

